

2013 Consumer Confidence Report Data WHITEWATER WATERWORKS, PWS ID: 26500562

Water System Information

If you would like to know more about the information contained in this report, please contact Rick Lien at (262) 473-0543.

Opportunity for input on decisions affecting your water quality

312 W. Whitewater Street, city council chambers. 1st and 3rd Tuesdays each month.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Source	Depth (in feet)	Status
5	Groundwater	657	Active
6	Groundwater	1019	Active
7	Groundwater	898	Active

Source ID	Source	Depth (in feet)	Status
8	Groundwater	800	Active
9	Groundwater	950	Active

To obtain a summary of the source water assessment please contact, Rick Lien at (262) 473-0543.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water

Term	Definition
	below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Microbiological Contaminants

Contaminant	MCL	MCLG	Count of Positives	Violation	Typical Source of Contaminant
Coliform (TCR)	presence of coliform bacteria in $\geq 5\%$ of monthly samples	0	1	No	Naturally present in the environment

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
TTHM (ppb)		80	0	8.6	6.1 - 8.6		No	By-product of drinking water chlorination
HAA5 (ppb)		60	60	1	0 - 1		No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
ARSENIC (ppb)		10	n/a	3	3 - 3		No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)		2	2	0.120	0.057 - 0.120	6/1/2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	1.6	0.2 - 1.6	6/1/2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)		100		4.0000	2.5000 - 4.0000	6/1/2011	No	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
NITRATE (N03-N) (ppm)		10	10	0.32	0.03 - 0.32		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SELENIUM (ppb)		50	50	3	0 - 3	4/26/2011	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)		n/a	n/a	13.00	6.80 - 13.00	4/26/2011	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.2700	0 of 30 results were above the action level.	7/28/2011	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	4.40	1 of 30 results were above the action level.	7/27/2011	No	Corrosion of household plumbing systems; Erosion of natural deposits

Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)		15	0	5.2	-0.3 - 5.2	9/12/2011	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)		5	0	5.4	3.3 - 5.4	9/12/2011	No	Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)		n/a	n/a	5.7	0.0 - 5.7	9/12/2011	No	Erosion of natural deposits
COMBINED URANIUM (ug/l)		30	0	0.8	0.4 - 0.8	4/26/2011	No	Erosion of natural deposits

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring.

Contaminant (units)	Level Found	Range	Sample Date (if prior to 2013)
SULFATE (ppm)	14.00	7.70 - 14.00	6/1/2011
BROMOCHLOROMETHANE (ppb)	0.20	0.20	7/19/2011

Volatile Organic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
P-DICHLOROBENZENE (ppb)		75	75	0.1	0.0 - 0.2		No	Discharge from industrial chemical factories
TOLUENE (ppm)		1	1	0.0002	0.0000 -		No	Discharge from

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2013)	Violation	Typical Source of Contaminant
					0.0008			petroleum factories

Health effects for any contaminants with MCL violations/Action Level Exceedances

Contaminant Health Effects

LEAD Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Whitewater Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Information on Monitoring for Cryptosporidium and Radon

Our water system did not monitor our water for cryptosporidium or radon during 2013. We are not required by State or Federal drinking water regulations to do so.

Other Compliance

Monitoring and Reporting Violations

Description	Contaminant Group	Sample Location	Compliance Period Beginning	Compliance Period Ending
Bacti M/R MIN	Microbiological	Distribution	12/1/2013	12/31/2013

Description	Contaminant Group	Sample Location	Compliance Period Beginning	Compliance Period Ending
Routine - Too few Routine samples	Contaminants	System		

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted in the above table, we did not complete all monitoring or testing for the contaminant(s) noted, and therefore cannot be sure of the quality of your drinking water during that time.

Actions Taken

Since some routine samples in Dec. 2013 were missed I have discussed this with the DNR Engineer. He advised me to monitor my sampler's submitted data on the DNR compliance site. I also have made changes to the sampler's data & recording process to better monitor the samples taken. Although not enough samples were taken during this time period, raw well samples were taken showing no bacteriological positives at the wellhead.